



FORM B 13.3
FIRE SAFETY CERTIFICATE RENEWAL (FSCR)
(See Rule 25)

Fire Safety Certificate Approval (FSCA) No. FSCA/O/CFOSMC/2024/00046888
FSC Safety Certificate Renewal (FSCR) No. FSCA/O/CFOSMC/2024/00046888/R1

Date: 12/02/2024

Building Occupancy/Category: Educational (non-residential)

To,

Ashutosh
THE MILLENNIUM SCHOOL, SURAT BLOCK NO-369, VILL. NARTHAN, B/S. PARAIZO CLUB, SURAT-DANDI ROAD, SURAT
SURAT Surat MC SUDA 395005
Fire Region: Surat MC
Mobile No: 9725683305 Email ID: administrator@themillenniumschoolorsurat.org

This has reference to your Application No. 2024/00047033 dated 05/02/2024 for Fire Safety Certificate Renewal (FSCR) for the building/premise THE MILLENNIUM SCHOOL, SURAT (name of the Building/ Project), as per below mentioned details:

1. TP Number:
2. FP Number:
3. Survey Number:
4. Village Name: SURAT
5. Name of Block(s): THE MILLENNIUM SCHOOL SURAT

The building/premise was inspected on 12/02/2024 and all fire prevention, life safety and fire protection measures provided were found to be in proper and effective working condition. There are no changes in building/premise use or occupancy or in building design or structure.

Further, the following activities (as applicable) have been carried out towards meeting requirements of GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 as amended, or the then applicable GDCR:

1. Emergency drill was carried out on 12/02/2024
2. Six monthly inspection was done on 12/02/2024

The Fire Safety Certificate is renewed for a period of two (2) years upto 12/02/2026 in accordance with GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 and their amendments.



Digitally Verified

Digitally verified by: Anil Nagjibhai Bharodiya
Fire Safety Officer - Specialist (FSO-S)
2021/001338

Date: 12/02/2024
Time: 12:53 PM



FSCA/O/CFOSMC/2024/00046888/R1

This is a digitally verified certificate, hence doesn't require physical signature. To validate authenticity of this certificate, scan the QR code or search the certificate details in appropriate section at www.gujfiresafetycop.in.

Please note that, apart from renewal, the building needs to be inspected every six months and a mock fire and emergency drill also needs to be conducted every six months. If there is a delay in scheduled inspection or mock drill, penalty shall be imposed. The Fire Safety Certificate renewal should be done timely after two years to avoid penalties.